
GENERATION IN PARALLEL WITH UTILITY SYSTEM NET METERING - WITH GENERATION METER

THIS SPECIFICATION SHOWS AN UNDERGROUND SERVICE WITH THE SOLAR METER LOCATED NEXT TO THE MAIN SERVICE METER. OTHER CONFIGURATIONS ARE POSSIBLE, BUT THE SOLAR METER MUST BE ELECTRICALLY CONNECTED ON THE UTILITY GRID SIDE OF THE INVERTER WITH THE SOLAR PANEL AS ITS SOURCE. CHECK WITH YOUR LOCAL UTILITY FOR MORE INFORMATION.



VERMONT UTILITIES ELECTRIC SERVICE REQUIREMENTS

DRAWN: <i>RJS</i>	DATE: 12-10-20
APPRVD: YES	DATE: 12-10-20
DRAWING No.: 408 PAGE: 2	
DATA BASE No.: DTW01912b	